



# Certificate of Compliance

## FIXED EXTINGUISHING SYSTEMS, CLEAN AGENT FIRE EXTINGUISHING SYSTEMS

This certificate is issued for the following product:

System Designation:	Fike FM-200 <sup>®</sup> Clean Agent Extinguishing Systems
System Type:	Engineered Systems
Agent Identification:	FM-200 <sup>®</sup>
Minimum and Maximum Agent Storage Temperatures:	32°F to 130°F (0°C to 54°C)
Minimum Design Concentrations for Hazard Class:	Class A – 6.25% Class B – 8.71%
Design, Installation, Operation, and Maintenance Manual:	Design, Installation & Maintenance Manual for Fike Clean Agent Systems w/ FM-200 <sup>™</sup> , GCA and DOT/TC Containers, P/N 06-215 Rev. F, June 2009

**Approved for:** FIKE CORPORATION  
704 SOUTH 10<sup>TH</sup> STREET  
BLUE SPRINGS, MO 64015  
UNITED STATES

FM Approvals confirms that the products above have been found to comply with the following standards:

UL 2166 – Standard for Halocarbon Clean Agent Extinguishing Units

Project Identifier: 3034276

Date of Approval: June 25, 2009

Richard B. Dunne  
Manager – Hydraulics Group, FM Approvals

6/25/09

Date



Member of the FM Global Group



# Certificate of Compliance

## FIXED EXTINGUISHING SYSTEMS, CLEAN AGENT FIRE EXTINGUISHING SYSTEMS

This certificate is issued for the following product:

System Designation:	Fike FM-200 <sup>®</sup> Clean Agent Extinguishing Systems
System Type:	Pre-Engineered Systems
Agent Identification:	FM-200 <sup>®</sup>
Minimum and Maximum Agent Storage Temperatures:	32°F to 130°F (0°C to 54°C)
Minimum Design Concentrations for Hazard Class:	Class A – 6.25% Class B – 8.71%
Design, Installation, Operation, and Maintenance Manual:	Design, Installation & Maintenance Manual for Fike Clean Agent Systems w/ FM-200 <sup>™</sup> , GCA and DOT/TC Containers, P/N 06-215 Rev. F, June 2009

**Approved for:** FIKE CORPORATION  
704 SOUTH 10<sup>TH</sup> STREET  
BLUE SPRINGS, MO 64015  
UNITED STATES

FM Approvals confirms that the products above have been found to comply with the following standards:

UL 2166 – Standard for Halocarbon Clean Agent Extinguishing Units

Project Identifier: 3034276

Date of Approval: June 25, 2009

A handwritten signature in black ink, appearing to read 'Richard B. Dunne'.

Richard B. Dunne  
Manager – Hydraulics Group, FM Approvals

6/25/09

Date



Member of the FM Global Group