



Certificate of Compliance

FIXED EXTINGUISHING SYSTEMS, CLEAN AGENT EXTINGUISHING SYSTEMS

This certificate is issued for the following:

System Designation:	Fike FM-200® Clean Agent Extinguishing Systems
Design, Installation, Operation, and Maintenance Manual:	Fike Corporation FM-200® With Impulse Technology Equipment, Design, and Service Manual, P/N 06-433, Rev 0, March 2010

Prepared for: FIKE CORPORATION
704 SOUTH 10TH STREET
BLUE SPRINGS, MO 64013

FM Approvals confirms that the products above have been found to comply with the following standards:
FM 5600 –Clean Agent Fire Extinguishing Systems, February 2009

Approval Identification: 3034180

Approval Granted: April 23, 2010

Said Approval is subject to satisfactory field performance, continuing follow-up Facilities and Procedures Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

For more than 160 years FM Approvals has partnered with business and industry to reduce property losses.

Richard B. Dunne
Group Manager- Hydraulics
FM Approvals
1151 Boston Providence Turnpike
Norwood, MA 02062

4/23/10

Date



Member of the FM Global Group