

## SF 1230™ CONTAINER RECHARGE KITS

### Description

After a system has been discharged, the container rupture disc valve must be rebuilt before the container can be recharged and placed back into service. The recharge kits contain all of the items required to rebuild the valve.

### Ordering

1-inch (25mm) Recharge Kit, P/N 85-049		
ITEM	DESCRIPTION	PART NUMBER
1	Friction Ring	70-2060
2	Disc Assembly	70-352
3	O-Ring	02-11987
4	Valve Core-Fill	02-4161
5	Reconditioning Instructions (not shown)	06-567

Note: 1 inch recharge kit is used on 5, 10, 20, 35, 60 & 100 lb. (2, 4, 8, 15, 27 & 44 L) containers.

3-inch (80mm) Recharge Kit, P/N 85-050		
ITEM	DESCRIPTION	PART NUMBER
1	Friction Ring	70-2063
2	Disc Assembly	70-353
3	O-Ring	02-11989
4	Valve Core-Fill	02-4161
5	Reconditioning Instructions (not shown)	06-567

Note: 3 inch recharge kit is used on 150, 215, 375, 650 & 1000 lb. (61, 88, 153, 267 & 423 L) containers

For a detailed procedure on recharging a Fike container with an Impulse Valve, refer to Fike's Recharge Manual (P/N 06-852).



### Approvals

- Underwriters Laboratories (UL)
- Underwriters Laboratories of Canada (ULC)
- Factory Mutual (FM)

For exact certification listings, please reference the respective agency web site.

### Contact Information

Fike Corporation – Global Headquarters  
 704 SW 10<sup>th</sup> Street  
 Blue Springs, MO 64015  
 Telephone: +1-816-229-3405  
[www.fike.com/contact-us](http://www.fike.com/contact-us) for global offices